

MOBILE FOOD VENDOR (MFV) FOOD TRUCK/CONCESSION TRAILER INSPECTION CHECKLIST

- COMPRESSED NATURAL GAS (CNG) PROPANE LEAK DETECTION INSIDE.
- PROVIDE 10 FEET DISTANCE FROM BUILDINGS, OTHER FOOD TRUCKS INCLUDING FOOD TRAILERS.
- WHEEL CHOCKS ARE REQUIRED.
- LPG GAS LINES THROUGH BULKHEADS SHALL BE BLACK PIPE.
- BAFFLE REQUIRED BETWEEN FRYERS AND OTHER COOKING APPLIANCES.
- KITCHEN SYSTEM FIRE SUPPRESSION SYSTEM TESTED WITHIN THE LAST 6 MONTHS.
- "K" TYPE FIRE EXTINGUISHER AVAILABLE AND SERVICED WITHIN THE LAST YEAR.
- (1) 10 LB. ABC TYPE FIRE EXTINGUISHER AVAILABLE AND SERVICED WITHIN THE LAST YEAR.
- PROOF OF CLEANING THE KITCHEN HOOD AND DUCTWORK.
- EXTERIOR ¼ TURN FUEL SHUT OFF LABELED WITH 4 INCH REFLECTIVE NUMERALS.
- LPG TANKS STORED IN CABINETS REQUIRE EXTERIOR VENTING.
- POST "NO SMOKING" WITH MINIMUM 2 INCH REFLECTIVE LETTERING.
- OUTDOOR LPG TANKS SHALL HAVE THE PRESSURE RELIEF VALVES POINTED AWAY FROM ENTRY DOORS.



___ FLEXIBLE CONNECTOR SHALL BE USED FROM THE LPG TANK AND NOT COPPER TUBING.

___ ALL APPLIANCES SHALL HAVE THE CORRECT KNOBS AND NUMBER FOR THAT APPLIANCE WITH NO USE OF PLIERS, WRENCHES NOR VISE GRIPS USED IN LIEU OF ANY MISSING KNOBS.

___ EXHAUST VENTS SHALL BE DIRECTED AWAY FROM CUSTOMERS.

___ GENERATORS SHALL OPERATE AT A NOISE LEVEL NOT EXCEEDING 80DB AND AT A DISTANCE OF 15 FEET AWAY FROM THE FOOD TRUCK/TRAILER.

___ METAL SAFETY CANS ARE REQUIRED FOR ADDITIONAL FUEL FOR THE GENERATOR. THE GENERATOR SHALL BE SHUT OFF WHILE REFUELING AND THERE SHALL BE A 15 MINUTE COOLING OFF PERIOD PRIOR TO REFUELING THE GENERATOR WITH AN ABC TYPE FIRE EXTINGUISHER AVAILABLE WHEN REFUELING.

___ THERE SHALL ALSO BE A REFLECTIVE SIGN STATING "FLAMMABLE GAS NO SMOKING" WITH A MINIMUM OF 2 INCH LETTERS.

SIGNATURE OF VENDOR

SIGNATURE OF FIRE OFFICIAL

PRINTED NAME

PRINTED NAME

PHONE NUMBER

DATE

(EXPIRES 6 MONTHS)